PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 26/06/2024

It is certified that an inspection team headed by Md. Abdu | Honnan AEE (Name of Officers with designation) from Mission Blog Youtha Crural water supply) inspected the E-TAKSHILA SCHOOL, Juzalpur (V), Narayankhed (M), Sangareddy (Dist), Telangana-502286 (Name & Address of the school) on 26/06/2024 (date of inspection) and found that the E-TAKSHILA SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/

State/ U.T. Govt.

The above is valid for a period of 1Year

Assistant Executive Engineer
Mission Bhagiratha (Intra)

Signature with Seal: Narayankhed Mandal

Name

Md-Abdul Hannan

Designation

: AEE

Name & Address of the Office / Department: Mission
Bhagiratha (Intra)

To

The Correspondent, E-Takshila School, Juzalpur (V), Narayankhed (M), Sangareddy (Dist), Telangana, 502286

(Name & Address of the Institution)

^{*} The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Manglain

Consultancy Services Hyderabad

(ISO 9001:2015 CERTIFIED & NABL ACCREDITED MATERIAL TESTING LABORATORY)

• Civil Engineering Material Testing • Destructive & Non Destructive Testing • Pile & Load Test

• Geotechnical Exploration • Geo-Physical Survey • Resistivity Survey • TPI • BI & BBD in Highway Testing

Test Report of Water sample to be Used for Drinking Purpose

TRF No

:- Water/2024/0011

Date of Report -26-06-2024

Report Ref No

:- MCS-HYD/2024-25/Reports/Lab/Water/20240627/0011

Name of Work

:- Provinding Drinking water Supply to E-Takshila school, at Juzalpur village of Narayanakhed mandal in

Sangareddy District...

Location of Sample

:- RO Tank in School

Test Started

:-19-06-2024

Test Completed

:-26-06-2024

Sample Quantity

:- 1 Lit

Test Results

5.No	Test Parameters	Test Method	Units	Results	Acceptable Limits (as per IS: 10500:2012
1	pH	APHA-4500-H-B		7.4	6.5-8.5
2	Color	APHA-2120-C	Hazen	1.0	Max.5.0
3	Electrical Conductivity	APHA-2510-B	μs/cm	384	
4	Turbidity	APHA-2130-B	NTU	1.0	Max. 1.0
5	Alkalinity to Phenolphthalein as CaCO3	APHA-2320-B	mg/l	Nill	-
6	Alkalinity to Methyl orange as CaCO3	APHA-2320-B	mg/l	104	Max.200
7	Total Dissolved Solids	APHA-2540-B	mg/l	253	Max.500
8	Total Hardness as CaCO₃	APHA-2340-B	mg/I	110	Max 200
9	Non Corbonate Hardness as CaCO ₃	4 - 10	mg/l	Nill	1 - 2
10	Calcium as Ca	APHA-3120 B	mg/l	28.4	Max. 75
11	Magnesium as Mg	APHA-3120 B	mg/l	9.5	Max. 30
14	Cholrides as Cl	APHA-4500CL-C	mg/l	50	Max. 250
15	Sodium as Na	APHA-3120 B	mg/l	34	
16	Potassium (K)	APHA-3120 B	mg/l	6.0	
17	Sulphates as SO ₄	APHA-4500-C	mg/l	22.4	Max. 200
18	Nitrates as NO ₃	APHA-4500-C	mg/l	14.2	Max. 45
19	Iron as Fe	APHA-3120 B	mg/l	0.1	Max. 1.3
20	Fluoride as F	APHA-4500-E	mg/l	0.3	Max. 1.0
	MIG	CROBIOLOGICAL ANALY	/SIS	10.4	
23	Total Bacterial Count at 37°c	15:5402-2012	Cfu/ml	44	-
24	Coli forms	ISO 9308-1	Per/100ml	Absent	Absent/100ml
25	Escherichia. Coli	ISO 9308-1	Per/100ml	Absent	Absent/100ml

Remarks:- The Properties of Water Sample conforms IS: 10500:2012 Specification Requirements and suitable for drinking

End of Report

Assistant Executive Engineer

Mission Bhagiratha (Intra) Hyderabal Office : Mandal Khammam Branch:

H.No. 11-13-824, Rd.No.-3, Green Hills Colony, Saroornagar - 500035 M.: 95503 38973

H.No. 15-17-135, Dwaraka Nagar M.: 9392914297 9550338973

Vijayawada Branch: H.No. 20, NSR Villas, Mangalagiri, A.P. M.: 9392914292/3 95503 38973

Nizamabad Branch: H.No. 11-1-215, Behind Reliance Super Mart, Kanteshwar. M.: 6301854414

Warangal Branch: H.No. 31-3-715, Road No. 19, Waddepally, Near Teja International mcslabtests@gmail.com High School, Hanumakonda. M.: 9392914295

Web: www.mcslabtests.com e-mail:





Scanned with OKEN Scanner



Manglam

Consultancy Services Hyderabad

(ISO 9001:2015 CERTIFIED & NABL ACCREDITED MATERIAL TESTING LABORATORY)

• Civil Engineering Material Testing • Destructive & Non Destructive Testing • Pile & Load Test

• Geotechnical Exploration • Geo-Physical Survey • Resistivity Survey • TPI • BI & BBD in Highway Testing

Note:

- 1. IS-Indian Standard, APHA- American Public Health Association
- 2. The Test Report is based on the sample received by our Laboratory.
- 3. <2 Result Indicates the minimum detection limit of Bacteria in given sample
- 4. Results are issued with specific understanding that MCS Hyderabad will not be in any case in action following the interpretation of test results.

For Manglam Consult

Authorised Signator

Services Hyderabad

sistant Executive Engineer Mission Bhagiratha (Intra) Narayankhed Mandal

Hyderabad Office: H.No. 11-13-824, Rd.No.-3, Green Hills Colony, Saroomagar - 500035

Khammam Branch: H.No. 15-17-135, Dwaraka Nagar M.: 9392914297

H.No. 20, NSR Villas, Mangalagiri, A.P. M.: 9392914292/3

Vijayawada Branch: | Nizamabad Branch: H.No. 11-1-215, Behind Reliance Super Mart, Kanteshwar.

Warangal Branch: H.No. 31-3-715, Road No. 19, Waddepally, Near Teja International mcslabtests@gmail.com High School, Hanumakonda.

Web: www.mcslabtests.com e-mail: APTS



Scanned with OKEN Scanner